

Construction Products Regulation EU 305/2011

Schneider Electric Fire & Security Oy DECLARATION OF PERFORMANCE No. DP20002GB

This document is a declaration of performance that the products identified below conform to the essential requirements that have been specified in the European Regulation 305/2011 covering construction products.

1. Unique identification code of the product-type:

Description: Heat Detectors, Short Circuit Isolators

Model number(s): EDE-221-I Esmi Essentia Heat Detector (FFS06720302)

Analogue Addressable Class P Heat Detector with Short Circuit Isolator

To be used in conjunction with the following base: FFS06720300

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the CPR:

Each individual product is identified with a label containing a production date code with build standard number

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

Fire detection and fire alarm systems

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):

Apollo Fire Detectors Ltd, 36 Brookside Road, Havant, Hampshire, PO9 1JR CC0321 and APOLBECN.01

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

Schneider Electric Fire & Security Oy Sokerilinnantie 11 C 02600 Espoo Finland

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

System 1

7. Notified Body:

DBI Certification A/S (Notified Body 2531)

EC Certificate Number(s): **2531-CPR-CSP10981**

8. European Technical Assessment:

Not applicable

9. Declared performance

Essential Characteristics	Standard EN 54-5: 2000 + A1:2002	Performance
Nominal activation conditions/Sensitivity. Response delay (response time) and Performance under fire conditions	4.2, 4.3, 5.2 to 5.6,5.8, 6.1,6.2	Pass
Operational reliability	4.4 to 4.11	Pass
Tolerance to supply voltage	5.7	Pass
Durability of operational reliability and response delay: temperature resistance	5.9,5.10	Pass
Durability of operational reliability: vibration resistance	5.14 to 5.17	Pass
Durability of operational reliability: humidity resistance	5.11, 5.12	Pass
Durability of operational reliability: corrosion resistance	5.13	Pass
Durability of operational reliability: electrical resistance	5.18	Pass

Essential Characteristics	Standard EN54-17:2005	Performance
Performance under fire conditions	5.2	Pass
Operational reliability	4	Pass
Durability of operational reliability: temperature resistance	5.4, 5.5	Pass
Durability of operational reliability: vibration resistance	5.9 to 5.12	Pass
Durability of operational reliability: humidity resistance	5.6, 5.7	Pass
Durability of operational reliability: corrosion resistance	5.8	Pass
Durability of operational reliability: electrical stability	5.3, 5.13	Pass

¹⁾ This is assuming that the effect of the fire is to cause a short circuit in the transmission path that is protected by these devices

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Espoo Finland 07.01.2020

Atte Pihlava

Product Manager