

PRODUCT-DETAILS

E6.2V 4000 Ekip Touch LSI 3p F HR

E6.2V 4000 Ekip Touch LSI 3p F HR



General Information

Extended Product Type	E6.2V 4000 Ekip Touch LSI 3p F HR
Product ID	1SDA071245R1
EAN	8015644750954
Catalog Description	E6.2V 4000 Ekip Touch LSI 3p F HR
Long Description	C.BREAKER SACE EMAX2 E6.2V 4000 FIXED THREE-POLE WITH TERMINALS REAR HORIZONTAL AND SOLID-STATE RELEASE IN AC EKIP/TOUCH-LSI R 4000 FITTED WITH: 4 AUXILIARY CONTACT AND C.BREAKER IN POSITION OPEN-CLOSED

ABB EcoSolutions

ABB EcoSolutions	Yes
------------------	-----

Circular Value

Circular Design Principles Recyclability Rate	Design for Closing Resource Loops - Standard EN45555 - 77 %
Conflict Minerals Reporting Template (CMRT)	9AKK108467A5658
End of Life Instructions	9AKK108468A2364
Group Waste to Landfill Target	UL 2799 Zero Waste To Landfill Validation available

Toxic Substances
Control Act - TSCA

9AKK108467A8326

Eco Transparency

Environmental Product Declaration - EPD	9AKK108468A1905
	9AKK108468A1913

Environmental

Environmental Information	9AKK10103A1038
	9AKK108467A6707
REACH Declaration	9AKK108466A1425
RoHS Information	9AKK108466A1424
RoHS Status	Following EU Directive 2011/65/EU and Amendment 2015/863 July 22, 2019

Ordering

Order Code US and Canada	Z6VWERBE000A000000XX
EAN	8015644750954
Minimum Order Quantity	1 piece
Customs Tariff Number	85362090

Dimensions

Product Net Width	762 mm
Product Net Height	371 mm
Product Net Depth / Length	270 mm
Product Net Weight	109 kg

Container Information

Package Level 1 Units	box 1 piece
Package Level 1 Width	515 mm
Package Level 1 Height	610 mm
Package Level 1 Depth / Length	1000 mm
Package Level 1 Gross Weight	118 kg
Package Level 1 EAN	8015644750954

Additional Information

Current Type	AC
Electrical Durability	Ue = < 440 V 4000 cycle Ue = 500 ... 690 V 4000 cycle 10 cycles per hour
Mechanical Durability	12000 cycle 60 cycles per hour
Number of Poles	3
Power Loss	309 W
Product Main Type	SACE Emax 2
Product Name	Air Circuit Breaker

Product Type	Air Circuit Breaker
Rated Service Short-Circuit Breaking Capacity, in % of I _{cs}	100 %
Rated Current (I _n)	4000 A
Rated Voltage (U _r)	690 V
Rated Impulse Withstand Voltage (U _{imp})	acc. to IEC 60947-2 12 kV
Rated Insulation Voltage (U _i)	AC 1000 V
Rated Operational Voltage	690 V AC
Rated Service Short-Circuit Breaking Capacity (I _{cs})	(220 V AC) 150 kA (230 V AC) 150 kA (380 V AC) 150 kA (400 V AC) 150 kA (415 V AC) 150 kA (440 V AC) 150 kA (500 V AC) 130 kA (660 V AC) 100 kA (690 V AC) 100 kA
Rated Short-time Withstand Current Low Voltage (I _{cw})	for 1 s 100 kA for 3 s 100 kA
Rated Ultimate Short-Circuit Breaking Capacity (I _{cu})	(400 V AC) 150 kA (415 V AC) 150 kA (440 V AC) 150 kA (500 V AC) 130 kA (525 V AC) 130 kA (690 V AC) 100 kA
Rated Uninterrupted Current (I _u)	4000 A
Recommended Screw Driver	Main Circuit M12
Release	Ekip Touch LSI
Release Type	EL
Short-Circuit Performance Level	V
Standards	IEC
Sub-type	E6.2
Terminal Connection Type	Rear flat Horizontal
Terminal Type	Bolt
Tightening Torque	70 N·m
Version	F
CAD Dimensional Drawing	1SDH001252R0223

Certificates and Declarations

ATEX Certificate	No certification needed
CSA Certificate	No certification needed
CSA Certificate (Intrinsic Safe)	No certification needed
Data Sheet, Technical Information	1SDC200023D0209
Declaration of Conformity - CE	9AKK106713A5544
UL Certificate	No certification needed
VDE Certificate	No certification needed
Mechanical Drawings	1SDH001060R0100

Wiring Diagram	1SDM000091R0001
Instructions and Manuals	1SDH001000R0002
Instructions and Manuals (Part 2)	1SDH001316R1002

Classifications

ETIM 7	EC000228 - Power circuit-breaker for trafo/generator/installation protection
ETIM 8	EC000228 - Power circuit-breaker for trafo/generator/installation protection
ETIM 9	EC000228 - Power circuit-breaker for trafo/generator/installation protection
Object Classification Code	Q
WEEE Category	4. Large Equipment (Any External Dimension More Than 50 cm)
eClass	V11.1 : 27370409

Categories

Low Voltage Products and Systems → Circuit Breakers → Air Circuit Breakers → Emax 2

