

UE DECLARATION OF CONFORMITY



No CE/EN/0640/V4/2022/560

Name and address of the manufacturer:

KANLUX SA, ul. Objazdowa 1-3, 41-922 Radzionków (POLAND)

This declaration of conformity is issued under the sole responsibility of the manufacturer.

Object of the declaration:

OVERCURRENT CIRCUIT BREAKER

Type/types:

**KMB6-Bx/1, KMB6-Bz/2, KMB6-Bz/3, KMB6-Bz/4,
KMB6-Cy/1, KMB6-Cz/2, KMB6-Cy/3, KMB6-Cz/4,
KMBN6-Cz/1**

x=1, 2, 6, 10, 13, 16, 20, 25, 32, 40, 50, 63; y= 4, 6, 10, 16, 20, 25, 32, 40, 50, 63;
z= 6, 10, 16, 20, 25, 32, 40, 50, 63

Trade mark:

IDEAL^{TS}

Basic parameters:

by **Kanlux**
Uc = 230/400V~ (1P), 400V~ (3P); In = 1..63A; Inc = 6000A;
B-, C- type; Energy limiting class - 3

Batch or serial number:

#DA3

The object of the declaration described above is in conformity with the relevant Union harmonisation legislation:

Directive (LVD) – 2014/35/EU

Directive (RoHS) – 2011/65/EU, (EU)2015/863

References to the relevant harmonised standards used or references to the other technical specifications in relation to which conformity is declared:

EN 60898-1:2019

EN IEC 63000:2018

Additional information:

Kanlux SA has an implemented Quality Management system according to norm **ISO 9001:2015** confirmed by ISO certificate PL006884/1/P issued by Bureau Veritas Certification Polska Sp. z o.o.

NWP/5709, NWP/5710, NWP/5714, NWP/5715; ID 0640; S.CE/560

Radzionków, 23.05.2022

Kanlux S.A.
Kierownik Laboratorium Badawczego
Krzysztof Żurek
(name) (function) (signature)

Kanlux S.A.
Dyrektor Działu Technicznego
Dariusz Staniczek
(name) (function) (signature)

Kanlux SA
Kierownik ds. Wdrożeń
i Certyfikacji Produktów
Adam Wabnic
(name) (function) (signature)

Kanlux SA 1-3 Objazdowa St., 41-922 Radzionków, Poland | ph. +48 32/388 74 00, fax +48 32/388 74 99 | kanlux@kanlux.com | kanlux.com