



We reserve the right to introduce changes in performance, configuration and technology, dimensions, weights and materials in the course of technical progress. The figures are shown without obligation.

1 Stk

The clamps must be designed for the same maximum short-circuit current as the earthing and short-circuiting cables!

PU